



589 Avenue D, Suite 10
PO Box 787
Williston, VT 05495

www.kas-consulting.com

802.383.0486 p

802.383.0490 f

July 26, 2023

Ms. Sandy Gregg
Town of South Hero
P.O. Box 175
South Hero, VT 05486

RE: Lead Based Paint Inspection – Old White Meeting House, 320 US-2, South Hero, VT

Dear Ms. Gregg:

KAS, Inc. (KAS) is pleased to present the attached report which outlines the results of the lead-based paint inspection conducted at 320 US-2, South Hero, VT on July 6, 2023.

In summary, lead in amounts equal to or greater than 1.0 mg/cm² was found in paint at various locations on the interior and exterior of the building.

Thank you for this opportunity to be of service. Please call me should you have questions.

Sincerely,

Jeremy Roberts, P.G.
Principal / Environmental Program Manager

Enc/ cc: KAS #307230415